

Certificate



for European Product Safety

Reference No. 1905113

Heating cable, serie-resistive

Type designation R-QN-N-*M2, R-QN-P-*M2

Certificate holder **nVent Nordic AB**
Flöjelbergsgatan 20B
431 37 Mölndal
SWEDEN

The product complies with the standard(s) IEC 60800:2009

Date of expiry 3 April 2024

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed



Henrik Wikström

Date 3 April 2019
Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

350

**Intertek
Appendix**

Reference No. 1905113

Technical data

Type designation	R-QN-N-*M2, R-QN-P-*M2
Rated Voltage (V)	230V
Number of Conductors	2 + screen
Rated power (W)	90-1600 W
Trade mark	nVent RAYCHEM
Product information	2 conductor series resistive. With splice and end seal. Mechanical class M1. Also for installation in screed or concrete. Minimum installation temperature: -5°C. Minimum bending diameter: 6 times cable diameter.
Others	"N" denotes power 90 W/m ² "P" denotes power 160 W/m ² "*" denotes area (1-12 m ²)

Manufacturing site(s) Pentair Water (Suzhou) Co., Ltd.
371 Heshan Road
215011 Suzhou, New District
CHINA

This certificate is based on Test Report with ref. No. 248125-TL6-2 dated 29 November 2018, issued by VDE.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed



Henrik Wikström

Date 3 April 2019

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.